



**PLANNING COMMITTEE:
23 APRIL 2020**

Report of: Director of Development and Regeneration

Contact: Mrs. C. Thomas (Extn.5134)
Email: catherine.thomas@westlancs.gov.uk

SUBJECT: ADDITIONAL LATE INFORMATION

1.0 INTRODUCTION

The information below has been received since compilation of your Agenda. The following also includes suggested adjustments to the recommendations further to the receipt of late plans and/or information.

2.0 ITEM 7 – PLANNING APPLICATIONS

**REPORT NO. 1 – LAND TO THE SOUTH OF NORTHFIELD, SKELMERSDALE
– 2019/0719/FUL**

The recommendation should read:

11.1 That the decision to grant planning permission be delegated to the Corporate Director Of Place And Community in consultation with the Chairman or Vice Chairman of the Planning Committee subject to the applicant entering into a planning obligation under S106 of the Town and Country Planning Act 1990 to require:

The terms and conditions of the affordable housing;

11.2 That any planning permission granted by the Corporate Director Of Place And Community pursuant to recommendation 11.1 above be subject to the following conditions:

**REPORT NO. 2 – SITE OF FORMER YEW TREE FARM, LIVERPOOL ROAD
SOUTH – 2019/1316/FUL**

I have received additional comments from United Utilities (22.04.2020) which can be summarised as follows:

For clarification, no surface water from the Yew Tree Farm development is interacting with United Utilities existing sewer network.

In regards to the foul flows, it is important to note that Burscough WwTW (also referred to as New Lane WwTW) is not over capacity. Investigations have shown there is sufficient capacity at the works to cope with flows from the new developments across Burscough.

A study has been undertaken to understand the impact on levels of service on the existing public sewer network. Funding has been approved and a project is in the very early design stages. The project will ensure that levels of service on the public sewer network are maintained.

With regard to the removal of surface water on Lordsgate Lane, this is still proposed to be removed from the combined sewer and is captured under a diversion application which is currently ongoing. The surface water will then travel through the Yew Tree Farm development to a culverted watercourse via a SuDS feature.

It is intended for the pumping station within the Yew Tree Farm development to be adopted.

OBSERVATIONS OF CORPORATE DIRECTOR OF PLACE AND COMMUNITY

The above comment confirms that United Utilities foresee no issue with the proposed development. I am satisfied that the proposed development conforms to the overall drainage strategy for Yew Tree Farm and provides the necessary infrastructure to ensure delivery of the development approved under the outline planning permission.